

SOLENOID CONTROLLED VALVE
(NOT CONTROLLED BY STAGER)

BRINE EJECTOR

BRINE

INLET


SERVICE

BRINE RECLAIM

SOFTENER W/ BRINE RECLAIM

PRINTED IN U.S.A.

NOTCH	POS.	FUNCTION	PORTS VENTED (NOTE 1)	VALVES OPEN
A	0	SERVICE	1,8	1,2
B	1	BACKWASH	2	3,4,2A
C				
D	2	BRINE	4,5	5,6,2A,(7)
E	3	DISPLACE	4,5	5,6,2A
F	4	RECLAIM BRINE	5,6	5,8,2A
G	5	FAST RINSE	4,8	1,6,2A
H				



NOTE:

1. ALL OTHER PORTS PRESSURIZED.
2. ALL VALVES (EXCEPT NO. 2A) NORMALLY OPEN, PRESSURE TO CLOSE. VALVE 2A NORMALLY CLOSED.
3. VALVE 2A REQUIRED FOR RAW WATER BYPASS DURING REGENERATION.
4. DRAIN LINE FLOW CONTROLLER NOT SHOWN.
5. VALVE NO. 7 SOLENOID CONTROLLED (NOT CONTROLLED BY STAGER).

A	INITIAL RELEASE	NONE	JWB	31JUL01	
REV	DESCRIPTION	ECO	DWN	DATE	APVD
		16605 West Victor Rd New Berlin, WI 53151 262-326-0100 www.aq-matic.com			
SOFTENER W/ BRINE RECLAIM					
SCALE N/A	DRAWN JWB	DATE 31JUL01	DWG. NO. 1078285		

BRINE RECLAIM (51-12 STAGER)

PT Watermart Perkasa
 Email: sales@water.co.id Phone: +62-21-316-1671
 Whatsapp (text only): +62815-8609-3500
 Website: www.water.co.id